


CSA Control Cable

1000V Teck90 Cables

Description	Part No.	No. of Cond.	Cable Weight		Inner Jacket OD		Armor OD		Outer Jacket		Maximum Pull Tension		Minimum Bend Radius	
			Lbs./1000 Ft.	kg/km	Inch	mm	Inch	mm	Inch	mm	Lbs.	N	Inch	mm

14 AWG Stranded (7x22) Bare Copper Conductors • 14 AWG Bare Copper Ground Wire**Aluminum Interlocked Armor • .045" (1.14mm) XLPE Insulation • PVC Inner Jacket • Black PVC Outer Jacket**


CSA C22.2#131	C5701	3	251	374	.47	11.94	.67	17.02	.73	18.54	162	721	9.2	233.68
FT4 Flame Test	C5702	4	301	448	.51	12.95	.71	18.03	.81	20.57	216	961	9.7	246.38



Rip Cord

HAZ LOC
CSA C22.2#0.3 Clause 4.31 Low Acid Gas**12 AWG Stranded (7x20) Bare Copper Conductors • 14 AWG Bare Copper Ground Wire****Aluminum Interlocked Armor • .045" (1.14mm) XLPE Insulation • PVC Inner Jacket • Black PVC Outer Jacket**


CSA C22.2#131	C5730	2	253	377	.48	12.19	.68	17.27	.74	18.80	172	765	9.3	236.22
FT4 Flame Test	C5731	3	291	433	.51	12.95	.71	18.03	.76	19.30	258	1148	9.7	246.38
	C5732	4	368	548	.59	14.99	.75	19.05	.85	21.59	344	1531	10.8	274.32



Rip Cord

HAZ LOC
CSA C22.2#0.3 Clause 4.31 Low Acid Gas**10 AWG Stranded (7x18) Bare Copper Conductors • 12 AWG Bare Copper Ground Wire****Aluminum Interlocked Armor • .045" (1.14mm) XLPE Insulation • PVC Inner Jacket • Black PVC Outer Jacket**


CSA C22.2#131	C5760	2	285	424	.56	14.22	.79	19.99	.70	17.71	296	1317	10.3	261.62
FT4 Flame Test	C5761	3	389	581	.59	14.99	.79	20.07	.85	21.59	444	1976	10.3	261.62
	C5762	4	460	687	.65	16.51	.85	21.59	.90	22.86	592	2634	11.5	292.10



Rip Cord

HAZ LOC
CSA C22.2#0.3 Clause 4.31 Low Acid Gas**8 AWG Stranded (7x16) Bare Copper Conductors • 10 AWG Bare Copper Ground Wire****Aluminum Interlocked Armor • .045" (1.14mm) XLPE Insulation • PVC Inner Jacket • Black PVC Outer Jacket**

CSA C22.2#131	C5583	2	407	607	.59	14.99	.78	19.81	.86	21.84	384	1709	10.6	269.24
FT4 Flame Test	C5581	3	471	703	.63	16.00	.83	21.08	.90	22.86	576	2563	10.8	274.32
	C5582	4	606	905	.69	17.53	.89	22.61	.97	24.64	768	3418	12.5	317.50



Rip Cord

Dual Rated 600V, 1000V
HAZ LOC
CSA C22.2#0.3 Clause 4.31 Low Acid Gas

XLPE = Cross-linked Polyethylene

Color Code: 2 conductors — Black, White (If required, a Red conductor can be used in place of White.)
 3 conductors — Black, Red, Blue (If required, a White conductor can be used in place of Blue.)
 4 conductors — Black, Red, Blue, White
 5 or more conductors — Black and numbered


CSA Control Cable

1000V Teck90 Cables

Description	Part No.	No. of Cond.	Cable Weight		Inner Jacket OD		Armor OD		Outer Jacket		Maximum Pull Tension		Minimum Bend Radius	
			Lbs./1000 Ft.	kg/km	Inch	mm	Inch	mm	Inch	mm	Lbs.	N	Inch	mm

6 AWG Stranded (7x14) Bare Copper Conductors • 8 AWG Bare Copper Ground Wire**Aluminum Interlocked Armor • .060" (1.53mm) XLPE Insulation • PVC Inner Jacket • Black PVC Outer Jacket**


CSA C22.2#131 FT4 Flame Test	C5590	2	567	844	.73	18.54	.99	25.15	1.10	27.94	610	2713	12.8	325.12
	C5591	3	685	1019	.78	19.81	1.04	26.42	1.15	29.21	915	4072	13.4	340.36
	C5592	4	927	1380	.89	22.61	1.15	29.21	1.24	31.50	1220	5429	14.9	378.46



Rip Cord

HAZ LOC
CSA C22.2#0.3 Clause 4.31 Low Acid Gas**4 AWG Stranded (7x12) Bare Copper Conductors • 8 AWG Bare Copper Ground Wire****Aluminum Interlocked Armor • .060" (1.53mm) XLPE Insulation • PVC Inner Jacket • Black PVC Outer Jacket**


CSA C22.2#131 FT4 Flame Test	C5601	3	961	1430	.91	23.11	1.17	29.72	1.23	31.24	1455	6475	15.2	386.08
	C5602	4	1202	1794	.91	23.11	1.25	31.75	1.33	33.78	1940	8633	16.2	411.48



Rip Cord

HAZ LOC
CSA C22.2#0.3 Clause 4.31 Low Acid Gas**3 AWG Stranded (7x11) Bare Copper Conductors • 6 AWG Bare Copper Ground Wire****Aluminum Interlocked Armor • .060" (1.53mm) XLPE Insulation • PVC Inner Jacket • Black PVC Outer Jacket**


CSA C22.2#131 FT4 Flame Test	C5611	3	1126	1681	.97	24.64	1.23	31.24	1.30	33.02	1836	8170	15.8	401.32
---------------------------------	--------------	---	------	------	-----	-------	------	-------	------	-------	------	------	------	--------



Rip Cord

HAZ LOC
CSA C22.2#0.3 Clause 4.31 Low Acid Gas**2 AWG Stranded (7x10) Bare Copper Conductors • 6 AWG Bare Copper Ground Wire****Aluminum Interlocked Armor • .060" (1.53mm) XLPE Insulation • PVC Inner Jacket • Black PVC Outer Jacket**

CSA C22.2#131 FT4 Flame Test	C5621	3	1291	1927	1.02	25.91	1.28	32.51	1.37	34.80	2316	10302	16.5	419.10
	C5622	4	1691	2524	1.12	28.45	1.38	35.05	1.48	37.59	3088	13736	17.7	449.58



Rip Cord

HAZ LOC
CSA C22.2#0.3 Clause 4.31 Low Acid Gas

XLPE = Cross-linked Polyethylene

Color Code: 2 conductors — Black, White (If required, a Red conductor can be used in place of White.)
 3 conductors — Black, Red, Blue (If required, a White conductor can be used in place of Blue.)
 4 conductors — Black, Red, Blue, White


CSA Control Cable

1000V Teck90 Cables

Description	Part No.	No. of Cond.	Cable Weight		Inner Jacket OD		Armor OD		Outer Jacket		Maximum Pull Tension		Minimum Bend Radius	
			Lbs./1000 Ft.	kg/km	Inch	mm	Inch	mm	Inch	mm	Lbs.	N	Inch	mm

1 AWG Stranded (19x14) Bare Copper Conductors • 6 AWG Bare Copper Ground Wire**Aluminum Interlocked Armor • .080" (2.03mm) XLPE Insulation • PVC Inner Jacket • Black PVC Outer Jacket**


CSA C22.2#131	C5625	3	1620	2411	1.25	31.75	1.51	38.35	1.59	40.39	1980	8807	19.1	485.14
FT4 Flame Test	C5626	4	2173	3234	1.34	34.04	1.57	39.88	1.68	42.67	2680	11921	20.2	513.08



HAZ LOC
CSA C22.2#0.3 Clause 4.31 Low Acid Gas

1/0 AWG Stranded (19x12) Bare Copper Conductors • 6 AWG Bare Copper Ground Wire**Aluminum Interlocked Armor • .080" (2.03mm) XLPE Insulation • PVC Inner Jacket • Black PVC Outer Jacket**


CSA C22.2#131	C5627	3	1912	2854	1.34	34.04	1.60	40.64	1.67	42.42	3582	15940	20.0	508.0
FT4 Flame Test	6164	4	2514	3742	1.44	36.58	1.67	42.42	1.78	45.21	4700	20906	21.4	543.56



HAZ LOC
CSA C22.2#0.3 Clause 4.31 Low Acid Gas

2/0 AWG Stranded (19x11) Bare Copper Conductors • 6 AWG Bare Copper Ground Wire**Aluminum Interlocked Armor • .080" (2.03mm) XLPE Insulation • PVC Inner Jacket • Black PVC Outer Jacket**


CSA C22.2#131	C5635	3	2300	3423	1.40	35.56	1.63	41.40	1.74	44.20	4200	12010	20.9	530.86
FT4 Flame Test	6157	4	3039	4523	1.55	39.37	1.84	46.74	1.95	49.53	5500	24465	23.4	594.36



HAZ LOC
CSA C22.2#0.3 Clause 4.31 Low Acid Gas

3/0 AWG Stranded (19x10) Bare Copper Conductors • 4 AWG Bare Copper Ground Wire**Aluminum Interlocked Armor • .080" (2.03mm) XLPE Insulation • PVC Inner Jacket • Black PVC Outer Jacket**


CSA C22.2#131	6163	3	2905	4324	1.51	38.10	1.80	45.72	1.91	48.26	5020	11121	22.9	579.12
FT4 Flame Test	6179	4	3700	5506	1.67	42.42	1.96	49.78	2.07	52.58	6500	28913	24.8	629.92



HAZ LOC
CSA C22.2#0.3 Clause 4.31 Low Acid Gas

4/0 AWG Stranded (19x9.5) Bare Copper Conductors • 4 AWG Bare Copper Ground Wire**Aluminum Interlocked Armor • .080" (2.03mm) XLPE Insulation • PVC Inner Jacket • Black PVC Outer Jacket**

CSA C22.2#131	6193	3	3450	5134	1.63	41.40	1.92	48.77	2.03	51.56	6650	29580	24.4	619.76
FT4 Flame Test														



HAZ LOC
CSA C22.2#0.3 Clause 4.31 Low Acid Gas

XLPE = Cross-linked Polyethylene

Color Code: 3 conductors — Black, Red, Blue (If required, a White conductor can be used in place of Blue.)
4 conductors — Black, Red, Blue, White